



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



RECEIVED
JUN 30 2022

NOTICE OF INSPECTION VEGETATION ANNUAL

Date: 6/21/2022

Facility / Site Location

HEADROYCE SCHOOL
4315 LINCOLN AVE
OAKLAND, CA 94602-2528

4286 WHITTLE AVE
OAKLAND CA

We have inspected your property for Vegetation Management compliance at:
4286 WHITTLE AVE on 6/21/2022

It has been determined that your property is **Compliant** at the time of inspection with the City of Oakland's Municipal Code and Chapter 49 of the 2019 California Fire Code for defensible space requirements.

Thank you for your cooperation in providing a fire safe environment for yourself and the Oakland community.

NOTE: All re-inspections will be charged an inspection fee as permitted in the Oakland Master Fee Schedule, regardless of the inspection results.

Register for a Fire ACA (Accela Citizen Access) account to obtain detailed information to your Fire inspection records. The registration provides transparent access to all your Fire records. See scheduled inspections, inspection results and photos taken during the inspections. You can also access and save/print inspection letters. Please visit <https://aca.accela.com/oakland> to register.

Visit <https://www.oaklandca.gov/services/wildfire-district-inspections> for more information. Vegetation inspection questions can also be directed to wildfireprevention@oaklandca.gov or 510-238-7388.

Questions about ACA registration can be directed to fireacasupport@oaklandca.gov

Sincerely,

Oakland Fire Department
Office of the Fire Marshal

APN: 029A136700330
Inspector Name: Battalion 4 Station 16A
Inspection Reference #: 19147232
Record #: FDV22-03996



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



RECEIVED JUN 30 2022

NOTICE OF INSPECTION VEGETATION ANNUAL

Date: 6/21/2022

Facility / Site Location

HEADROYCE SCHOOL
4315 LINCOLN AVE
OAKLAND, CA 94602-2528

4180 WHITTLE AVE
OAKLAND CA

We have inspected your property for Vegetation Management compliance at:
4180 WHITTLE AVE on 6/21/2022

It has been determined that your property is **Compliant** at the time of inspection with the City of Oakland's Municipal Code and Chapter 49 of the 2019 California Fire Code for defensible space requirements.

Thank you for your cooperation in providing a fire safe environment for yourself and the Oakland community.

NOTE: All re-inspections will be charged an inspection fee as permitted in the Oakland Master Fee Schedule, regardless of the inspection results.

Register for a Fire ACA (Accela Citizen Access) account to obtain detailed information to your Fire inspection records. The registration provides transparent access to all your Fire records. See scheduled inspections, inspection results and photos taken during the inspections. You can also access and save/print inspection letters. Please visit <https://aca.accela.com/oakland> to register.

Visit <https://www.oaklandca.gov/services/wildfire-district-inspections> for more information. Vegetation inspection questions can also be directed to wildfireprevention@oaklandca.gov or 510-238-7388.

Questions about ACA registration can be directed to fireacasupport@oaklandca.gov

Sincerely,

Oakland Fire Department
Office of the Fire Marshal

APN: 029A138000103
Inspector Name: Battalion 4 Station 16A
Inspection Reference #: 19147216
Record #: FDV22-03980



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



RECEIVED JUN 30 2022

NOTICE OF INSPECTION VEGETATION ANNUAL

Date: 6/21/2022

Facility / Site Location

HEAD ROYCE SCHOOL
4315 LINCOLN AVE
OAKLAND, CA 94602-2528

4200 WHITTLE AVE
OAKLAND CA

We have inspected your property for Vegetation Management compliance at:
4200 WHITTLE AVE on 6/21/2022

It has been determined that your property is **Compliant** at the time of inspection with the City of Oakland's Municipal Code and Chapter 49 of the 2019 California Fire Code for defensible space requirements.

Thank you for your cooperation in providing a fire safe environment for yourself and the Oakland community.

NOTE: All re-inspections will be charged an inspection fee as permitted in the Oakland Master Fee Schedule, regardless of the inspection results.

Register for a Fire ACA (Accela Citizen Access) account to obtain detailed information to your Fire inspection records. The registration provides transparent access to all your Fire records. See scheduled inspections, inspection results and photos taken during the inspections. You can also access and save/print inspection letters. Please visit <https://aca.accela.com/oakland> to register.

Visit <https://www.oaklandca.gov/services/wildfire-district-inspections> for more information. Vegetation inspection questions can also be directed to wildfireprevention@oaklandca.gov or 510-238-7388.

Questions about ACA registration can be directed to fireacasupport@oaklandca.gov

Sincerely,

Oakland Fire Department
Office of the Fire Marshal

APN: 029A136700803
Inspector Name: Battalion 4 Station 16A
Inspection Reference #: 19147219
Record #: FDV22-03983



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



RECEIVED JUN 30 2022

NOTICE OF INSPECTION VEGETATION ANNUAL

Date: 6/21/2022

Facility / Site Location

HEAD ROYCE SCHOOL
4315 LINCOLN AVE
OAKLAND, CA 94602-2528

4220 WHITTLE AVE
OAKLAND CA

We have inspected your property for Vegetation Management compliance at:
4220 WHITTLE AVE on 6/21/2022

It has been determined that your property is **Compliant** at the time of inspection with the City of Oakland's Municipal Code and Chapter 49 of the 2019 California Fire Code for defensible space requirements.

Thank you for your cooperation in providing a fire safe environment for yourself and the Oakland community.

NOTE: All re-inspections will be charged an inspection fee as permitted in the Oakland Master Fee Schedule, regardless of the inspection results.

Register for a Fire ACA (Accela Citizen Access) account to obtain detailed information to your Fire inspection records. The registration provides transparent access to all your Fire records. See scheduled inspections, inspection results and photos taken during the inspections. You can also access and save/print inspection letters. Please visit <https://aca.accela.com/oakland> to register.

Visit <https://www.oaklandca.gov/services/wildfire-district-inspections> for more information. Vegetation inspection questions can also be directed to wildfireprevention@oaklandca.gov or 510-238-7388.

Questions about ACA registration can be directed to fireacasupport@oaklandca.gov

Sincerely,

Oakland Fire Department
Office of the Fire Marshal

APN: 029A136700802
Inspector Name: Battalion 4 Station 16A
Inspection Reference #: 19147222
Record #: FDV22-03986



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



**NOTICE OF INSPECTION
VEGETATION ANNUAL**

Date: 6/27/2022

Facility / Site Location

HEADROYCE SCHOOL
4315 LINCOLN AVE
OAKLAND, CA 94602-2528

4233 LINCOLN AVE
OAKLAND CA

We have inspected your property for Vegetation Management compliance at:
4233 LINCOLN AVE on 6/27/2022

It has been determined that your property is **Compliant** at the time of inspection with the City of Oakland's Municipal Code and Chapter 49 of the 2019 California Fire Code for defensible space requirements.

Thank you for your cooperation in providing a fire safe environment for yourself and the Oakland community.

NOTE: All re-inspections will be charged an inspection fee as permitted in the Oakland Master Fee Schedule, regardless of the inspection results.

Register for a Fire ACA (Accela Citizen Access) account to obtain detailed information to your Fire inspection records. The registration provides transparent access to all your Fire records. See scheduled inspections, inspection results and photos taken during the inspections. You can also access and save/print inspection letters. Please visit <https://aca.accela.com/oakland> to register.

Visit <https://www.oaklandca.gov/services/wildfire-district-inspections> for more information. Vegetation inspection questions can also be directed to wildfireprevention@oaklandca.gov or 510-238-7388.

Questions about ACA registration can be directed to fireacasupport@oaklandca.gov

Sincerely,

Oakland Fire Department
Office of the Fire Marshal

APN: 029A136700601
Inspector Name: Battalion 4 Station 16A
Inspection Reference #: 19150429
Record #: FDV22-07971



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



NOTICE OF INSPECTION VEGETATION RE-INSPECTION

Date: 7/1/2022

Facility / Site Location

HEADROYCE SCHOOL
4315 LINCOLN AVE
OAKLAND, CA 94602-2528

4282 WHITTLE AVE
OAKLAND CA

We have inspected your property for Vegetation Management compliance at:
4282 WHITTLE AVE on 7/1/2022

It has been determined that your property is **Compliant** at the time of inspection with the City of Oakland's Municipal Code and Chapter 49 of the 2019 California Fire Code for defensible space requirements.

Thank you for your cooperation in providing a fire safe environment for yourself and the Oakland community.

NOTE: All re-inspections will be charged an inspection fee as permitted in the Oakland Master Fee Schedule, regardless of the inspection results.

Register for a Fire ACA (Accela Citizen Access) account to obtain detailed information to your Fire inspection records. The registration provides transparent access to all your Fire records. See scheduled inspections, inspection results and photos taken during the inspections. You can also access and save/print inspection letters. Please visit <https://aca.accela.com/oakland> to register.

Visit <https://www.oaklandca.gov/services/wildfire-district-inspections> for more information. Vegetation inspection questions can also be directed to wildfireprevention@oaklandca.gov or 510-238-7388.

Questions about ACA registration can be directed to fireacasupport@oaklandca.gov

Sincerely,

Oakland Fire Department
Office of the Fire Marshal

APN: 029A136700331
Inspector Name: VMD 3
Inspection Reference #: 19169173
Record #: FDV22-03993


Signature Responsible Party:

Name:

Responsible person not on site.

Signature Inspector:

Name: VMD 3

A handwritten signature in black ink, appearing to read "Hi VMD 3". The "Hi" is written in a simple, blocky font, and "VMD 3" is written in a more cursive, flowing style.

VMD 3

51. Tree crowns extending to within 10 feet of any structure shall be pruned to maintain a minimum horizontal clearance of 10 feet. (CFC 4907.3.1.1)

STATUS : Compliant


COMMENT : INSPECTOR COMMENT: Trees overgrown on roof line

LOCATION: When facing the front of the property, the violation is on the Rear of the property.

CFC REFERENCE: Cut back all portions of trees to provide 10 foot clearance from roof line to create as much "cold-air" space as possible between the structure and vegetation. It is not necessary to remove entire trees. See our website for more information.

FDV22-03993-20220701075419_1 - (CFC 4907.3.1.1)

Fri, 01 Jul 2022 - 07:54 AM




FDV22-03993-20220701075448_2 - (CFC 4907.3.1.1)

Fri, 01 Jul 2022 - 07:54 AM



FDV22-03993-20220701075518_3 - (CFC 4907.3.1.1)

Fri, 01 Jul 2022 - 07:55 AM



10.360 Degree Access

STATUS : Yes

COMMENT : INSPECTOR COMMENT:

LOCATION: N/A

CFC REFERENCE: (null)

Fire-Photos-Vegetation Re-inspection-Compliant-FDV22-03993-029A136700331 - 4282 WHITTLE AVE-20220701075537-19169173 - 19169173

Fri, 01 Jul 2022 - 07:55 AM